


Class 150 (Standard)

FIG. 3121

Coupling



For Listings/Approval Details and Limitations, visit our website at www.anvilintl.com or contact an Anvil® Sales Representative.

FIGURE 3121 - COUPLING

Nominal Size	Dimension A	Approx. Wt. Each
<i>In. (mm)</i>	<i>In. (mm)</i>	<i>Lbs. (kg)</i>
1/8 6	0.96 24.38	0.05 0.02
1/4 8	1.06 26.92	0.08 0.04
3/8 10	1.16 29.46	0.12 0.05
1/2 15	1.34 34.04	0.17 0.08
3/4 20	1.52 38.61	0.27 0.12
1 25	1.67 42.42	0.43 0.20
1 1/4 32	1.93 49.02	0.65 0.29
1 1/2 40	2.15 54.61	0.86 0.39
2 50	2.53 64.26	1.35 0.61
2 1/2 65	2.88 73.15	2.33 1.06
3 80	3.18 80.77	3.36 1.52
4 100	3.69 93.73	5.59 2.54

MATERIAL SPECIFICATIONS

Dimensions: Fittings: ASME B16.3
 Unions: ASME B16.39
 Bushings/Plugs: ASME B16.14

Material: ASTM A-197

Finish: Black or Hot Dip Galvanized per ASTM A153 Class A

Threads*: NPT per ASME B1.20.1

Pressure Ratings: Fittings: ASME B16.3
 Unions: ASME B16.39
 Bushings/Plugs: ASME B16.14

Pressure Testing: All malleable iron fittings are tested for through wall porosity using an air under water process.

Agency Approvals: All malleable iron fittings and unions are UL/ULC Listed and FM Approved.

* British Standard threading per BS 21 available upon request.

PROJECT INFORMATION

APPROVAL STAMP

Project:	<input type="checkbox"/> Approved
Address:	<input type="checkbox"/> Approved as noted
Contractor:	<input type="checkbox"/> Not approved
Engineer:	Remarks:
Submittal Date:	
Notes 1:	
Notes 2:	