CATALOG NUMBER

ECLK2

electri Center ACCESSORIES

Neutral Lug Kit Wire Range: #4 - 2/0 AWG

Same As:

■ LK2 ■ ELK2

■ DLK2



LUG KIT INSTALLATION INSTRUCTIONS



A DANGER

Hazardous Voltage.
Will cause death, serious injury or substantial property damage.

Turn off power supplying this equipment before working inside.

▲ SAFETY INSTRUCTIONS

Note: This instruction outlines the recommended installation procedure.

- 1. Turn off and lock off the power supplying this equipment before working inside.
- 2. Remove 3 screws from neutral bar at location desired for mounting lug kit.
- 3. Position lug on center hole.
- 4. Secure lug to neutral bar with flat head screw. Torque screw to 40-50 lb.-ins.
- 5. Insert set screw in lug.

See wiring diagram for wire range size and tightening torque requirements.







