



**Replacement of Optima Plus RESS Module to G2 Module EBV-146-A**

**1** **Removal of Optima Plus RESS Module**

**A.** With water supply and pressure turned off, remove Locking Ring by turning counterclockwise.

**B.** Remove Outer Cover.

**C.** Remove RESS Module.

**2** **G2 Module Preparation**

**A.** Remove tape and magnet entirely from Module. Start up Mode will activate (sensor flashes continuously).

**B.** It is normal to find water inside bottom hole.

**3** **Installation of G2 Module**

**A.** Seat G2 Module onto Diaphragm Assembly.

**B.** Seat Outer Cover over G2 Module.

**C.** Install and tighten Locking Ring securely.



any  
 questions  
**?**

The information contained in this document is subject to change without notice.

- We recommend that you review our Royal G2 Optima Plus Installation Instructions and Maintenance Guides for complete instructions including Rough-in Dimensions, Specifications, Troubleshooting Guide, and Replacement Parts.
- Call our Installation Engineers for additional information at 1-888-SLOAN-14 or fax them at 1-800-737-3061.